



NOTES: TREATED WOOD BLOCKING, CONCRETE MASONRY UNITS, ETC., CAN BE SUBSTITUTED FOR P.I.P. CONCRETE CURB.

DETAIL DESIGNED TO ACCOMMODATE MAX. 50% TOTAL MOVEMENT.

DIAMETER OF FOAM ROD OR TUBE SHOULD BE 1" LARGER THAN MAXIMUM AS-BUILT JOINT OPENING.



Monolithic
Membrane
6125-FR
ROOFING SYSTEMS

AMERICAN HYDROTECH, INC.

FIELD EXPANSION JOINTS
1"-2" MAX. AS-BUILT WIDTHS

3"=1'-0"

R-6B